

FIRE SAFETY CERTIFICATE

No.

Dated: 22-08-2024

Certified that the Sri Venkateshwarra Srinivasa Ramanujan Educational Society (name of the building or premises) at Unikichella, Dharmasagar Hanamkonda (address) comprised of 01 basement(s) and 01 (upper floors) owned/ occupied by Srinivasa Ramanujan High School (name of the institution) have complied with the fire prevention and fire safety requirements in accordance with rule of State/ UT Fire Service Rules, and verified by the officers concerned of Fire Service on 15.08.2024 (date of inspection) in the presence of Mucha Aruna (name and addresses of the Manager/ Secretary or his representative) and that the building/ premises is fit for occupancy upto classes X (XI XII) With effect from 22.08.2024 for a period of One year in accordance with rule and subject to compliance of specific conditions as appended:-

- 1.
- 2.
- 3.
- 4.

Issued on 22.08.2024 (date of issue) at Hanamkonda (place) by

*Strike out whichever is not applicable.

Signature with Seal:

[Signature]
District Fire Officer
Fire Prevention Wing
Municipal Corporation, Warangal

Name

Shankar Lingam
District Fire Officer
Fire Prevention Wing

Designation

Sub-Inspector
Municipal Corporation, Warangal

Name & Address of Department/ Office:

Municipal Corporation Warangal

To

Srinivasa Ramanujan High School.

(Name & Address of the Institution)

ENDORSEMENT

The No Objection Certificate issued by Fire Service stand cancelled and annulled due to
.....
(reasons to be recorded).

(Name and designation of the authorized signatory)

* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

GREATER WARANGAL MUNICIPAL CORPORATION

From
The Commissioner,
Greater Warangal Municipal Corporation,
Warangal.

To
Mucha Aruna,
H.No. 1-105/2C,
Unikicherla, Dharmasagar.
Hanumakonda

RC.No.HO/GWMC/DFO/E-141311/SCHL/2024, Date: 22.08.2024

Sub: Greater Warangal Municipal Corporation – Fire Prevention Wing –Issuance of Renewal of No objection certificate for occupancy to the M/s Srinivasa Ramanujan High School, H.No. 26-3-312, Unikicherla, Dharmasagar, Hanumakonda mandal & district – Reg.

Ref: 1. RC.No. 5041/B2/97, Dt: 12-03-2010 of Director General, A.P. State Disaster Response and Fire Services, A.P. Hyderabad.

2. Application of the Principal Smt. Mucha Aruna, Dt.23.04.2024.

3. Note approval of Commissioner, GWMC via file no.E-141311, Date: 21.08.2024.

4. Renewal of NOC for Occupancy from Disaster Response & Fire Services Department vide 0005536 & 0005537/RENEWAL/Warangal-Urban/2018, Dt.18.10.2018.

Vide reference 2nd cited, the Principal Smt. Mucha Aruna has submitted an application for requesting to issue Renewal of NOC for Occupancy to the existing educational occupancy(B1) building of M/s Srinivasa Ramanujan High School, H.No. 26-3-312, Unikicherla, Dharmasagar, Hanumakonda mandal & district. Under the powers delegated vide reference 1st cited, the Officers of Fire Prevention Wing, GWMC, Warangal have inspected the school on 08.07.2024 and submitted the following report.

The management has previously obtained Renewal NOC for occupancy vide reference 4th cited to the Non Multi storied building with Ground+1 Upper Floors with a height of 7.00 Mts respectively for educational occupancy(B1).

1) Means of Escape & Floor Wise Details

Sl. No.	Floor Type	Type of Occupancy	Built Up Area in Sq. Mts	Occupant Load	Means of Escape Required in Mts	Means of Escape Provided In Mts
1	Ground Floor	Educational (B1)	931.00	233	NA	NA
2	First Floor	Educational (B1)	465.60	116	2.32	3.00

2) Stair Cases (As per NBC 2005)

Sl. No.	Type of Staircase	No. of Staircases	Width	Floor from	Floor to
1	Internal Staircase	1 No's	1.50 Mts	Ground	Terrace
2	External Staircase	1 No's	1.50 Mts	Ground	Terrace

3) Open Spaces & Gate Width

	Sl. No.	Open Spaces	Required	Provided	Deficit
a	1	NORTH	6.00 Mts	6.00 Mts	Nil
	2	SOUTH	6.00 Mts	6.00 Mts	Nil
	3	EAST (Front)	6.00 Mts	6.00 Mts	Nil
	4	WEST	6.00 Mts	6.00 Mts	Nil
b	Sl. No.	Gate Width (As per NBC 2005)	Required	Provided	Deficit
	1	Entry gate width	4.50 Mts	4.50 Mts	Nil
	2	Entry Gate Head Clearance	5.00 Mts	5.00 Mts	Nil

4) Travel distance & Dead end of the corridor

Sl. No.		Required	Provided	Deficit
1	Farthest point (Most Remote Point) Within a storey or a mezzanine floor to the door to an Exit.	30 Mts	29 Mts	Nil
2	The Dead end of the corridor length in exit access. (not exceeding 06 meters for Educational, Institutional and Assembly, 15mtrs for other Occupancies)	6.00 Mts	6.00 Mts	Nil

5) Fire Fighting Installations as per Table 7 of NBC 2005

Sl. No.	Fire Fighting System	Required	Provided
1	Fire Extinguishers	8 No's	8 No's
2	First Aid Hose Reel	2 No's	2 No's
3	Down comer	1 No's	1 No's
4	Terrace Tank	5000 Lts	5000 Lts
5	Terrace Pump/ Booster Pump	450 LPM	450 LPM

The management has remitted fire prevention fee vide GWMC Cash receipt No. 139769, Dt: 23.04.2024 for Rs. 22,500/- (Rupees Twenty Two thousand five hundred only).


The management has provided fire safety systems and life safety measures such as means of escape, travel distance and dead end of the corridor as per the provisions of the National Building Code, 2005.

1. The NOC issued is confined to the Fire Safety measures to be installed in the building and does not confer any Legal right for claiming of Ownership of property or Conversion of land use/ Occupancy or building Regularization. The owner / Occupier shall comply the Building Rules Govt. Orders as applicable.
2. Evacuation plan showing exist routes and recommended action plan be displayed at conspicuous locations and shall be exhibited at all times, all escape / exit routes shall not be locked or encroached.
3. Fresh NOC would be required for any change in occupancy or addition / alterations in the building structure as per NBC and building bye/laws.
4. The Management has to maintain Fire Safety Measures at all times in good working condition as seen during the inspection.
5. Any Loss of life or property due to Non- functioning of Fire Safety Measures and other installations shall be the responsibility of the management/ owner.
6. All the Occupants must know the correct method of operation of the Fire Fighting System installed.
7. Additional / Alteration, if any, in the building may be verified by building authority.
8. The Fire Drills shall be conducted once in every three months for initial two years, thereafter once in every 6 months.

The Renewal of NOC for occupancy is valid for the period of 1(one) year from the date of issue, it is responsibility of the owner/occupier to apply renewal of fire NOC one month before expiry of above NOC.

(This is approved by the Commissioner, GWMC Warangal vide e-office No:141311, dated:21-08-2024)

Sd/-Ashwini Tanaji Wakade, I.A.S
Commissioner
Greater Warangal Municipal Corporation


District Fire Officer
Fire Prevention Wing
Municipal Corporation, Warangal
22/08/2024